



IES INDOOR REPORT
PHOTOMETRIC FILENAME : 387CFL26C.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-1995
[TEST] 20865B
[MANUFAC]LDPI - VAPORPROOF - CFL CEILING
[LUMCAT]387-CFL26-C
[LUMINAIRE]WITH CLEAR LINEAR PRISMATIC GLASS JAR LENS AND DIE CAST GUARD
[LAMP]ONE 26 WATT CPFL LAMP. LUMEN RATING = 1800 LMS.
[OTHER]SIMULATED REPORT FROM TEST WITH 42 WATT LAMP

CHARACTERISTICS

Total Rated Lamp Lumens	1800
Total Luminaire Efficiency	67.6 %
Luminaire Efficacy Rating (LER)	45
Total Luminaire Watts	27
Ballast Factor	1.00
CIE Type	General Diffuse
Spacing Criteria (0-180)	N.A.
Spacing Criteria (90-270)	N.A.
Spacing Criteria (Diagonal)	N.A.
Basic Luminous Shape	Point
Luminous Length (0-180)	0.00 ft
Luminous Width (90-270)	0.00 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	0	0	0
55	0	0	0
65	0	0	0
75	0	0	0
85	0	0	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 387CFL26C.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-30	42.35	2.4	3.5
0-40	92.94	5.2	7.6
0-60	270.03	15	22.2
0-90	678.37	37.7	55.7
90-120	379.44	21.1	31.2
90-130	460.31	25.6	37.8
90-150	533.45	29.6	43.8
90-180	539.1	29.9	44.3
0-180	1217.47	67.6	100

Total Luminaire Efficiency = 67.6%

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	3.51
10-20	11.81
20-30	27.03
30-40	50.6
40-50	75.73
50-60	101.36
60-70	124.63
70-80	140.47
80-90	143.24
90-100	142.14
100-110	129.67
110-120	107.63
120-130	80.87
130-140	51.06
140-150	22.07
150-160	5.21
160-170	.43
170-180	.01


IES INDOOR REPORT
PHOTOMETRIC FILENAME : 387CFL26C.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC RW	80				70				50			30			10			0
	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	73	73	73	73	68	68	68	68	59	59	59	50	50	50	42	42	42	38
1	63	58	54	50	58	54	50	46	45	42	40	37	35	33	30	28	27	23
2	56	48	43	38	51	45	39	35	37	33	29	30	27	24	24	22	19	16
3	50	41	35	29	45	38	32	27	31	27	23	26	22	19	20	17	15	12
4	45	36	29	24	41	33	27	22	27	22	18	22	18	15	17	14	12	9
5	41	31	25	20	37	29	23	18	24	19	15	19	15	12	15	12	9	7
6	37	28	21	16	34	25	19	15	21	16	13	17	13	10	13	10	8	6
7	34	25	18	14	31	23	17	13	19	14	11	15	12	9	12	9	7	5
8	32	22	16	12	29	20	15	11	17	13	9	14	10	7	11	8	6	4
9	29	20	14	10	27	19	13	10	15	11	8	13	9	6	10	7	5	3
10	27	18	13	9	25	17	12	8	14	10	7	12	8	6	9	6	4	3

POLAR GRAPH



Maximum Candela = 133.5 Located At Horizontal Angle = 0, Vertical Angle = 77.5

- # 1 - Vertical Plane Through Horizontal Angles (0 - 180)
- # 2 - Vertical Plane Through Horizontal Angles (45 - 225)
- # 3 - Vertical Plane Through Horizontal Angles (90 - 270)